

c/50

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/ 219

Dated: 16/04/2021

To,

The Principal,
Modern International School,
Sector-19, Dwarka, Phase-1,
New Delhi-11075.

Subject: Renewal of Fire Safety Certificate iro Modern International School, Located at Sector-19, Dwarka, Phase-1, New Delhi-11075.

Sir,


Please refer to your letter no. Email Dated 15/03/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 26-03-2021 in presence of Mr. Ravinder Kumar (Employee) for fire safety point of view. During the course of inspection the following shortcomings are noticed.

1. Exhaust fans provided in basement found removed/ inadequate.
2. One Hose Reel Hose found provided at floor but it does not cover entire area of the floor an additional Hose Reel must be provided at each floor.
3. Only one Terrace pump most probably of 180 LPM was seen at terrace. One more pump of 900 LPM must be provided at terrace. All the pumps must be functional in auto mode.
4. Only two fire water tank of 5000 ltrs capacity were seen at terrace. One more fire water tank of 5000 ltrs capacity must be provided at terrace. All the tanks must be interconnected to each other.
5. One Swimming pool & temporary rooms were seen in the premises. It has not been shown in the approved plans.
6. A portion of the buildings is being used as a bank.
7. Dully fill up Form J & K are not submitted.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire officer
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054

12016
7/14