

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/2021/ 217

Dated: 16 /04/2021

To

- The Principal,  
 AVB Nursery School,  
 F-272, Laxmi Nagar, Delhi-92.

**Sub: Regarding Fire Safety Certificate in r/o AVB Nursery School located at F- 272,  
 Laxmi Nagar, Delhi-110092.**

Sir,

This has reference to email dated 22/02/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 02/03/2021 in the presence of Mr. Satish Sharma (Incharge) and the following shortcomings were observed :-

- 1. Additional staircase of width 0.75 mtr. not provided up to 2<sup>nd</sup> floor.
- 2. For additional 3<sup>rd</sup> floor 2 staircase of 1.5 meter are not provided.
- 3. Hose reel/hydrant not provided.
- 4. Pump of capacity 450 LPM is not provided.
- 5. Overhead tank of capacity 10,000 lit is not provided.
- 6. Exit signage not provided.
- 7. Submit as built drawing of the building.

Hence, renewal of Fire Safety Certificate can not be considered at this stage.

Yours faithfully

  
13/4/21

**(Dr. S.K. Tomar)**  
 Dy. Chief Fire Officer  
 Delhi Fire Service



Copy to:-

The Director (Education),  
 Govt. of NCT, Old Sectt.  
 Delhi - 54.