

c/26

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. 26/D&S/ms/school/N.D.2/2021/215

Dated 16/04/2021

To,

The Principal,
EDMC Primary School,
O- Block, Sunder Nagri,
Delhi 110093

Sub:- Regarding Issuance Fire Safety Certificate.

Sir,

This is in reference to your email ID edmcpsnno01@gmail.com dated 22/12/2020 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned EDMC Primary School from fire safety point of view in presence of Mrs. Deepa Rani Gupta, Principal of the School. During the course of inspection it was observed that the following points / shortcomings were noticed in the building comprised of ground plus two upper floors.

1. Only 06 fire extinguisher provided in place of 14 fire extinguishers as required.
2. First-Aid hose reels (01 nos.) not provided at each floor as required.
3. A fire pump having 450 LPM output at 40 meters head not provided.
4. Exit Signage were not provided.
5. Overhead tank 10,000 ltr.cap.is not provided.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully


13/4/21

(Dr. S.K.Tomar)
Dy.Chief Fire Officer



Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92