

e/16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
DIRECTORATE OF DELHI FIRE SERVICE : NEW DELHI-110001

No. 26/DFS/MS/2021/School/220

Dated 19/04/2021

To

The Manager,
Nalanda Convent School, D-5, School Road,
Om Nagar, Badarpur, New Delhi-110044.

Sub:- Fire Safety Certificate regarding Fire Safety for running in r/o Nalanda Convent School, D-5, School Road, Om Nagar, Badarpur, New Delhi-110044.

Sir,

Please refer to your letter received through email ID-newnalandapublicschool090@gmail.com 01/04/2021 on the subject cited above. In this connection it is to inform you that the school premises was visited by the officer concerned of this department on 03/04/2021 in the presence of Sh. Sanjay Singh (Manager) and observed that the shortcomings issued by this department vide letter No. F6/DFS/MS/School/2018/SZ/5028 dated 14/12/2018. (Copy Enclosed) still not complied.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER.

Copy to :-

1. Director of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002.

[Handwritten initials]

C-6

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2018/SZ/ 5098

Dated: 14/12/18

To

The Manager,
Nalanda Convent School,
D/5, School Road, Om Nagar,
Badarpur, New Delhi-110044

Sub: Reg. Issuance of NOC in r/o Nalanda Convent School, D-5, School Road, Om Nagar, Badarpur, New Delhi-110044.


Sir,

This is in reference with your letter No. NCS/2018/15 dated 15.03.2018 received in outdoor dairy vide No. 4091 dated 16.03.2018 on the subject cited above. In this connection, it is to inform you that premises visited by the officer concerned of this department on 18/07/2018 in the presence of Mr. Sanjay (Admin) to verify the compliance of shortcomings communicated by this department vide letter No.F.6/DFS/MS/School/2015/174 dated 23/01/2015 and observed that there have been addition of 2nd floor in the building. The building now comprises of basement, ground plus two upper floors. The shortcomings observed are as below;

1. Year of construction of second floor with supporting documents.
2. Width of staircases in basement found less than 1.5m; one of the staircases shall be 1.5m wide.
3. Terrace level pump having cap. 360 LPM with 30m head found provided against required 900 LPM with 40m head.
4. Over head water storage capacity 7,000 liters found provided against 15,000 liters.
5. Exit signage not provided at each floor.
6. You are requested to inform the use of basement & area in the school.

In view of above, renewal of FSC cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,



(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225

Copy to: -

1. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002