

0/23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2021/224

Dated: 19/04/2021

To

The Principal,
S.D. Sr. Sec. Public School,
2783, Cheerakhana, Nai Sarak, Delhi-06

Subject:-Regarding issuance of Fire Safety Certificate in r/o **S.D. Sr. Sec. Public School, 2783, Cheerakhana, Nai Sarak, Delhi-06**


Madam,

With reference to your email dated 31.03.2021 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (SPM) from this department on 09.04.2021 in the presence of Mrs. Kiran Kaul (Principal), and it was observed that the school building is comprised of ground + 04 upper floors. During the inspection, following shortcomings were observed:-

1. The School building is not accessible to fire engines as approach road width is less than 6 meters.
2. The alternate exit (width – 0.75 cm) is provided till 2nd floor only. The same shall approach to all floors.
3. First Aid Hose reel is not provided.
4. Fire pump having capacity 450 LPM is not provided.
5. Over head water storage tank of 10,000 liters capacity exclusively for firefighting, is not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


15/4/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Tel: 011-23412025

etc 
15/4

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi