

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 212

Dated: 16/04/2021

To

The HOS / Vice Principal,  
Sarvodaya Kenya Vidyalaya,  
New Friends Colony,  
New Delhi - 110025

Sub: Reg. renewal of Fire Safety Certificate in r/o Sarvodaya Kenya Vidyalaya, New Friends Colony, New Delhi - 110025


Sir,

This has reference with your Gmail dated 10/02/2021 on the subject cited above. In this regard, school premises have been inspected by officer concerned of this department on dated 27.03.2021 in presence of Mrs. Indra Sagar (Vice Principal) to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. Hose reel found non-functional in old block, ground plus two & new block ground plus three upper floor
2. Terrace pumps found non-functional in old block, ground plus two & new block ground plus three upper floor

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat Delhi 110054