

10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2021/SZ/ 213

Dated: 16/04/2021

To

The HOS / Vice Principal,
Veer Chander Singh Garhwali,
Govt. Sarvodaya BAL Vidyalaya,
J Block, Saket New Delhi

Sub: Reg. renewal of Fire Safety Certificate in r/o Veer Chander Singh Garhwali, Govt. Sarvodaya BAL Vidyalaya, J Block, Saket New Delhi (ID 1923056)

Sir,

This has reference with your letter no VCSG/SBV/J- block/Saket/74 dated 22/02/2021 on the subject cited above. In this regard, school premises have been inspected by officer concerned of this department on dated 02.04.2021 in presence of Dr. Vijay Kumar Kaushik to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. Hose reel found non-functional in old block, (ground plus two) & new blocks ground plus three upper floors two blocks in the building.
2. Terrace pumps found non-functional in old block, (ground plus two) & new blocks ground plus three upper floors two blocks in the building

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat Delhi 110054