

2117

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE:
NEW DELHI – 110001

No.F6/DFS/MS/School/MN/2021/281

Dated: 20/05/2021

To

The Principal,
Sarvodaya kanya Vidyalaya,
Moti Nagar,
New Delhi-110015

Sub: - Regarding Issuance of NOC fire safety point of view in r/o of Sarvodaya kanya Vidyalaya, Moti Nagar, New Delhi-110015

Sir,

Please refer to your Email dated 08/03/2021 on the subject cited above. In this connection, it is to inform that the premises was inspected by the officer concerned of this department on 15/04/2021 in the presence of Sh. Suresh Kumar Soni (Estate Manager) to check the shortcomings already issued by this department Vide letter No. F6/DFS/MS/2012/4509 dated 07/12/2012. During inspection; it has been observed that the school building has Four Blocks. One Block is comprised of Ground + one floor with single staircase of 178 cm namely (main building). Second block (namely Pink building) is comprised of Ground + three upper floors with single staircase of 156 cm both are interconnected by corridor. Third Block (namely Primary Wing) is comprised of Ground + one upper floor with single Staircase of 153 cm & Forth Block (namely Middle Wing) is comprised of Ground +one upper floor with two staircase width of 155 cm each. The premises is approachable to Fire unit through 610 cm wide gate. Fire safety arrangements such as Fire Extinguishers, Hose reels, etc. are provided. However the status of shortcoming are as under:-

S.N.	Shortcomings	Status
1.	The Systems Such as hose reel, internal hydrant, yard hydrant found provided were not in working condition	Not Rectified
2.	Single Door is provided in some of class rooms against required two doors where students are more than 45.	Rectified

In addition to the above, the following shortcomings were also observed.

1. Over Head water storage tank capacity of 10,000 ltrs is removed.
2. Terrace pump found provided but not working/functional.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The Licensing authority /statutorily authority may take suitable necessary action as deemed fit.

Yours Faithfully

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. Director of Education, Old Secretariat, Civil Lines, Delhi-110054.

dk
18/5/2021