

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/School/2021/SZ/ 35

Dated 21/01/2021

To,

The Principal,
Holy World School, Arjun Park,
Ishwar Colony, New Delhi-110043.

Sub: - Regarding grant of NOC from fire safety point of view in r/o Holy World School,
Arjun Park, Ishwar Colony, New Delhi-110043.

Sir,

Please refer to your letter no. Nil Dated 22/12/20 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above-mentioned Educational building from fire safety point of view. During the course of inspection, the following points / shortcomings were noticed:

1. First Aid Hose Reels provided but not functional.
2. Fire Pump with auto starting having 450 LPM output with 30 M head provided but not functional.
3. Exits signage's are not provided.

In view of above, the educational building cannot be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

Director of Education,
Govt of NCT of Delhi, Old Secretariat,
New Delhi-110054.