

0121

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2021/WZ/ 293

Dated: 27/05/2021

To,

The Principal,
Vyas Public School,
D-87, Yadav Nagar,
Delhi-110042,

Sub: Issue of FSC in r/o Vyas Public School, D-87, Yadav Nagar, Delhi-110042.

Sir,

Kindly reference to Online e-mail dated 22.01.2021 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 30.03.2021, in presence of Sh. Sanjay Vyas, Owner to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Terrace pump found non-functional at the time of inspection.
2. 6000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs
3. Details for year of construction for addition of 2nd floor & room on terrace are not provided & stair case with of alternate stair case is less than 1.5 meters.
4. Further, you are advised to submitted fresh building plans on the scale of 1:00, duly marked with fire and life safety provision to this department for further consideration in this matter.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

Yours faithfully

(Atul Garg)
DIRECTOR

Ph; 011-23414000

96
04