

9/18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
DIRECTORATE OF DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/BP/2021/ 99

Dated: 24 .02.2021

To,


The Authorised Signatory,  
Blooming Buds Educational & Welfare Society (Regd.),  
A-64, Pushpanjali Enclave, Pitampura, New Delhi-110034.

Subject: Regarding request to review the requirement of U/G Fire Water Storage Tank of 2 Lakh Liters for Nursery School at Block-A, Pocket-D, Shalimar Bagh, New Delhi having basement area 400 Sq.mtrs. comprised of Basement +Stilt+G+2 floors,

Sir,

This has reference to your letter no. Nil dated 15.01.2021 on the subject cited above. In this connection it is to inform you that reply vide letter no. F6/DFS/MS/2021/45 dated 29.01.2021 has already been sent to you, by this department. However, a photocopy of the same is attached for your information.

Yours faithfully,

  
(Virendra Singh)  
Dy. Chief Fire Officer  
Delhi Fire Service

Encl: As mentioned above.

San  
23/02/2021 @  
70/2

415

Frequent hand sanitization-wearing of face mask-keep physical distance to prevent from Covid-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
DIRECTORATE OF DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/2021/ 45

Dated: 29 .01.2021

To,

The Authorised Signatory,  
Blooming Buds Educational & Welfare Society (Regd.),  
A - 64, Pushpanjali Enclave, Pitampura, New Delhi-110034.


Sub:- Request for review the requirement U/G Fire Water storage tank of 2 Lakh litres & Pump of 2280 LPM for Nursury School at Plot No NS-4, Block - A, Pocket - D, Shalimar Bagh, New Delhi-110088.

Sir,


This has reference to your letter no. Nil dated 15.01.2021 and email dated 18.01.2021 on the subject cited above. In this connection it is to inform you that this department has already issued fire safety guidelines vide letter No. F6/DFS/MS/2019/BP/213 dated 06-06-2019 as per the category of occupancy and provisions of National Building Code of India Part-4/Unified Building Bye laws-2016, wherein sprinkler system was recommended for basement floor. The covered area of basement floor is 426.85 m<sup>2</sup>. As the covered area of basement floor exceeds 360 m<sup>2</sup>, therefore provisions for sprinkler system was recommended in accordance with IS-15105/2002.

Therefore, in view of the above you are requested to abide by the fire safety directives, issued vide letter No. F6/DFS/MS/2019/BP/213 dated 06-06-2019 in letter and spirit.

Yours faithfully,

  
(Virendra Singh)

Dy. Chief Fire Officer  
Delhi Fire Service

  
28/1/2021