

c/20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/ 301

Dated: 15/06/2021

To,

The Principal,
Govt. Co- Ed. Senior Secondary School,
Sector -06, Site-II,
New Delhi – 110075.

Subject: Renewal of Fire Safety Certificate iro Govt. Co- Ed. Senior Secondary School, (ID-1821031) Located at Sector -06, Site-II New Delhi – 110075.

Sir,

Please refer to your letter no. GCOED/SSS/DWK/S-VI/817 dated 09/03/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 06/04/2021 in presence of Dr. Ritu Kumari (V. Principal) for fire safety point of view.

During the course of inspection the following shortcoming were observed.

1. Hose Reel Hoses found damaged / missing.
2. Terrace pump of 450 LPM found non functional.
3. Exits signage found removed.
4. The new blocks comprising of ground plus one upper floor should not be used without getting FSC from this department.

You are requested to comply the abovementioned shortcomings under intimation with this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire officer
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054

Handwritten initials and date: 10/6/21