

633

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/HQ/2021/ 304

Dated 21 / 06 /2021

To,

The Principal
Guru Harkishan Public School,
Nanak Piao, Delhi-110033.

Sub: - Regarding issuance of fire safety certificate in r/o Guru Harkishan Public School, Nanak Piao, Delhi-110033.

Sir,

Please refer to your letter received through email I.D dated 09.03.2021 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 12.04.2021 to verify the fire safety measures issued vide Director of Education and observed that the school premise is comprised of basement, ground and one upper floors. At the time of inspection Sh. Paramjeet Singh (Attendant) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. Smoke ventilation not provided in basement.
2. Fire extinguisher provided but not functional at the time of inspection.
3. MOEFA system not provided.
4. Sprinkler system not provided in basement.
5. Terrace level fire fighting pumps capacity of 450 lpm provided but not functional.
6. Terrace level water tank capacity of 10,000ltr provided but found empty and foundation damage condition.
7. Exit signage and floor signage not provided at strategic locations in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage

Yours faithfully

(Dharampal Bhardwaj)

Dy. Chief Fire Officer

Ph:-011-25156707

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.