

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/School/2021/305

Dated: 23/06/2021

To,

The Principal,
Govt. Girls Sr. Sec. School,
Jafrabad Extension, Delhi-110032

Sub:- Fire NOC letter 2021.

Sir,

With reference to email ID No. 1105114hos@gmail.com dated 06/04/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Rashmi Rani, principal, of the school on dated 15/06/2021. The school building comprises of ground plus three upper floors(New building). During the course of inspection following observations were made:-

1. Firefighting system which has been provided in the building, was not found functional at the time of inspection.
2. Exit Signs are required to be provided in the school building at all exits.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer



Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053