

193

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2021/NDZ/School/ 306

Dated: 23/06/2021

To,

The Vice Principal
Govt. Girls Sec. School,
Welcome Colony, Delhi-110053

Sub:- Renewal of Fire Safety Certificate (NOC).

Sir,

With reference to letter No. GGSS/WC/2021/02 dated 15/04/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school building on 15/06/2021, it was noted that the shortcomings issued vide letter No. F6/DFS/MS/School/2021/50 dated 02/02/2021 have not been complied as yet (The copy of the same is enclosed for reference).


In view of the above Fire Safety Certificate cannot be considered at this stage. You are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Yours Faithfully,


22/06/21

(Dr. S. K. Tomar)

Dy. Chief Fire Officer



Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053

C-38

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/School/2021/ 50

Dated: 2/2/21

To,
The Principal,
Govt. Girls Sec. School,
Welcome colony, Delhi-110053

Sub:- Renewal of Fire Safety Certificate (NOC).

Sir,

With reference to your letter No. GGSS/WC/2020/30 dated 13/11/2020 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Mr. Inderjeet Kr. Jain, Estate Manager, of the School on dated 09/12/2020. The School building comprises of ground plus three upper floors, two separate blocks (new building). During the course of inspection following observations were made:-

1. Firefighting system which has been provided in the building, was not found functional at the time of inspection.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053

