

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
DIRECTORATE OF DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/BP/2021/ 128
To

Dated: 25.06.2021

Shri Keshavula Ashok Kumar, Sr. Architect, North,
Public Works Department, GNCT of Delhi,
6th Floor, MSO Building, I. P. Estate,
New Delhi- 110002.

Sub:-Clearance of building plans from fire safety point of view in r/o proposed construction of Educational building-training Centre at Indira Nagar, Azadpur, Delhi.


Sir,

Please refer to your **Request ID No. PWD/Fire/2021/06/3/159(62405.1)**, dated **24.06.2021** of online building plans, on the subject cited above. In this connection, this is to inform you that the referred online building plans in respect of proposed construction of Educational building-training Centre at Indira Nagar, Azadpur, Delhi, have been scrutinized from fire and life safety point of view and observed following shortcomings:-

1. One staircase is proposed against the requirement of two numbers of staircases of 1.5 meters wide each as per UBBL-2016.
2. Width of the access road is not mentioned on the plans.

In view of the above, the building plans are hereby rejected with a request to resubmit plans after rectification of above shortcomings for further consideration in the matter.

Yours faithfully,



(Atul Garg)

Director
Delhi Fire Service

