

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2021/NDZ/School/ 317

Dated: 29/06/2021

To,

The Principal,
Rattan Devi Arya Girls Sr. Sec. School,
Krishna Nagar, Delhi-110051

Subject:- Regarding to issue Fire Safety Certificate to School.

Sir,

With reference to letter No. RAGS/2021-22/560 dated 27/04/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school building on 18/06/2021, it was noted that the shortcomings issued vide letter No. F6/DFS/MS/School/2013/2344 dated 27/09/2013 and No. F6/DFS/MS/School/2019/NDZ/3055 dated 22/05/2019 have not been complied as yet (The copy of the same is enclosed for reference).


In view of the above Fire Safety Certificate cannot be considered at this stage. You are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Yours Faithfully,


28/6/21

(Dr. S. K. Tomar)

Dy. Chief Fire Officer



Copy to:-

The Joint Director of Education,
(Land & Estate) Directorate of education,
Lucknow Road, Delhi-110054

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2019/NDZ/ 3055

Dated: 22/5/19

To,

The Principal,
Rattan Devi Arya Girls Sr. Sec. School,
Krishna Nagar, Delhi-51.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Rattan Devi Arya Girls Sr. Sec. School, Krishna Nagar, Delhi-51.

Sir,

This has reference to your letter no RAGS/2019-20/08 dated 10/04/19 on the subject captioned above. In this connection, it is to inform you that the school was inspected by the officer concerned of this department in the presence of Manager verify the compliance of shortcomings already communicated by this department vide letter no.F6/DFS/MS/School/2013/2344 dated 27/09/13 same is not rectified.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further course of action.

Yours faithfully



(Sunil Chawdhary)
Dy. Chief Fire Officer

o/c

Copy to:-

1. The Joint Director of Education,
(Land & Estate) Directorate of education,
Lucknow Road Delhi-54.

c/10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001
Email - dcfondz.dlfire@nic.in

No. *F6/DfS/MS/School/2013/2344*

Dated: *27/09/13*

To,

The Principal,
Rattan Devi Arya Girls Sr. Sec. School,
Krishna Nagar, Delhi-51.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Rattan Devi Arya Girls Sr. Sec. School, Krishna Nagar, Delhi-51.

Madam,

Please refer to your letter no. RAGS/2013-14/219 dated 02.08.13 on the subject cited above, In this connection this is to inform you that officer concerned of this department inspected the school to verify the fire safety arrangements as per circular No. 262-362 dated 17.01.2005 issued by Director of Education. At the time of inspection Mrs. Praveen Kumari (HOS) of the School was present and it was observed that the school building is comprised of ground plus one upper floor has following shortcomings.

1. Four more fire extinguishers are required.
2. Five fire extinguishers are found provided but not maintained
3. Hose reel is found provided but not functional.

In view of above, the fire safety certificate cannot be issued. Therefore you are suggested to rectify the above said shortcoming under the intimation to this department for further course of action.

Yours faithfully


(Rajesh Panwar)

Dy. Chief Fire Officer
Delhi Fire Service

Ph. 23412025

gc
Real
25/9/13

Copy to:-

The Joint Director of Education
(Land & Estate)
Directorate of Education, Lucknow Road, Delhi -54.