

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2021/SZ/ 326

Dated: 02/07/2021

To

Authorized Signatory,
Delhi Cantonment Board,
Sadar Bazar, Delhi Cantt -110010.

Sub.:- NOC in r/o C.B. Sec. School (New Building), Uri Enclave, Delhi Cantt, New Delhi-110010.

Sir,

With reference to your letter No DCB/8/C/Engg./School/Fire/2020-21-90 dated 31/03/2021 on the subject noted above, in this connection it is to inform you that the said building premises was inspected by the officer concerned of this department on 16.06.2021 in the presence of Mrs. Vinod Kumar (HOS).

During the course of inspection it was observed that the building premises is comprised of Ground Floor & 2nd Floor Only.

However following shortcomings were observed during the time of inspection:-

1. Fire Extinguishers not provided.
2. Hose Reel Hose not provided.
3. Fire Pump of 450 Lit/min capacity not provided.
4. Overhead tank capacity of 10,000 ltr not provided.
5. Exit Signage not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR.

Copy to :-

1. Director of Education, Old Secretariat, Civil Lines, Delhi-110054.
2. Principal, C.B. Sr. Secondary School, Sadar Bazar, Delhi Cantt, New Delhi-110010.