

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F.6/DFS/MS/School/2021/NDZ/ 330

Dated:- 05/07/2021

To,  
The Principal,  
Guru Nanak Girls Sr. Sec. School,  
Gandhi Nagar, Delhi-110031

**Subject:-Renewal of Fire Safety Certificate of Guru Nanak Girls Sr. Sec. School,  
Gandhi Nagar, Delhi-110031.**

Sir,

With reference to email id gngschool33@gmail.com dated 18/03/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Harvinder Kaur, Principal of the school on dated 23//06/2021. The school building comprises of ground plus three upper floors. During the course of inspection following observations were made:-

1. The firefighting system which has been provided in the school building, was not functional at the time of inspection.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,

*S. K. Tomar*  
17/21

(Dr. S. K. Tomar)  
Dy. Chief Fire Officer

*Dr. S. K. Tomar*

Copy to:-  
The Joint Director of Education (Land & Estate),  
Director of Education  
Lucknow Road,  
Delhi -110054