

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

G19

No. F6/DFS/MS/SCHOOL/WZ/2021/342

Dated: 12/07/2021

To,

The Principal,
S. D. M. C. Primary School
Vishal Enclave, New Delhi-110027

Subject: Regarding renewal of NOC from fire safety point of view in respect of: S.D.M.C.
Primary School located at Vishal Enclave, New Delhi-110027.

Sir,

Please refer to your Email Dated 18/06/2021 on the subject cited above. In this connection, it is informed that the said school premises was inspected by the officer concerned of this department on 29/06/2021 in the presence of Ms. Hira Ram (Attendant) to check the workability of existing fire safety arrangements. During inspection, it has been observed that the said building is comprised of Ground plus two upper floors. Fire Safety arrangements such as Fire Extinguishers, First Aid hose reels, Terrace Pump, Over Head water storage tank & Exit signage are provided. However the following shortcomings were observed.

1. Hose Reel Hose of 30 mtrs length at each floor is provided (but found leakage).
2. Terrace Fire Pump of 450lpm provided but not on auto mode.
3. Overhead water storage tank of capacity 10000 ltrs is provided but not exclusive for Fire Fighting Purpose.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The Licensing authority /statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Dharampal Bhardwaj)
Dy. Chief Fire Officer,
Delhi Fire Service

Copy to:- The Directorate of Education Old Secretariat Delhi – 110054

o/c
SPD
09/07/2021