

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F.6/DFS/MS/School/2021/NDZ/ 351

Dated:- 16/07/2021

To,
The Principal,
Arwachin Bharti Bhawan Sr. Sec. School,
Vivek Vihar, Delhi-110095

Subject:- Renewal of NOC fire safety certificate.

Sir,

With reference to email arwachinschool@gmail.com dated 26/06/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Mr. Ravi Chauhan, caretaker of the school on dated 06//07/2021. The school building comprises of two block 1st block basement, ground plus two upper floors & 2nd block ground plus three upper floors. During the course of inspection following observations was made:-

1. The firefighting system which has been provided in the school building, was not functional at the time of inspection.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Dy. Director of Education,
D-Block, Anand Vihar, Delhi