

G12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2021/ 346

Dated: 14/07/2021

To,
The Principal,
EDMC Nigam Pratibha Vidyalaya,
Sadatpur (II) Shahdara North,
Delhi 110094

Sub:- Regarding Issuance of Fire Safety Certificate in r/o EDMC Nigam Pratibha Vidyalaya, Sadatpur (II) Shahdara North, Delhi 110094.

Sir,
With reference to your email letter No. nil dated 17/03/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view in presence of Mr. Manoj, Teacher of the School to verify the compliance of shortcomings already communicated by this department vide letter No. F6/DFS/MS/School/2013/2528 dated 14/11/13 and was observed that following shortcomings have not been complied.

1. First Aid Hose reel not provided.
2. A fire pump having 450 LPM output at 40 meters head not provided.
3. Over head tank 10,000 liter not provided.
4. Exit signage not provided.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service


Copy to:-
The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92