

C-8

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No.F6/DFS/MS/School/2021/ 345

Dated 14/07/2021

To,

The Manager,  
Happy Time Public School,  
D-Block, Bhajanpura,  
Delhi-110053

Sub:- Regarding Issuance Fire Safety Certificate in r/o Happy Time Public School at D-Block, Bhajanpura, Delhi-110053


Sir,

This is in reference to your email letter no. nil dated 01/02/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view in presence of Mr. Pranav Sharma, Manager of the School. The following points / shortcomings were noticed in the building comprised of ground plus three upper floors.

1. Width of one staircase 1.50 meter shall be required.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully



(Atul Garg)  
Director

Delhi Fire Service



o/c

Copy to:-

The Dy. Director of Education,  
B- Block, Yamuna Vihar  
Delhi-110053