

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2021/ 347

Dated: 14/07/2021

To,

The Principal
J. R. International Public School
Milan Garden, Sabhapur, Delhi-110094

Sub:- Regarding Issuance of Fire Safety Certificate in r/o M/s J. R. International Public School located at Milan Garden, Sabhapur, Delhi-110094.

Sir,

With reference to your email letter No. nil dated 14/04/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view in presence of Mr. Pramod Kumar Kundliwal, Manager of the School. During the course of inspection it was observed that the following points / shortcomings were noticed in the building comprised of ground plus one upper floor.

1. The width of staircase is not as per prescribed norms. The width of staircase shall be increased to 1.50 meter or an additional staircase of 0.75 meter shall be provided.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Station

Copy:-

The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053