

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/WZ/2020/ 14

Dated: - 05/01/2021

To

The HOS,  
Sarvodaya Vidyalaya,  
Mundka, New Delhi- 110041.

Sub.-: Regarding issuance of Fire Safety Certificate in r/o Sarvodaya Vidyalaya, Munkda, New Delhi- 110041.

Sir,

Please refer to your E-mail received through ID [gskvmundka\\_1617014@yahoo.com](mailto:gskvmundka_1617014@yahoo.com) dated 12.11.2020, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in your presence, on 03.12.2020 to check the fire safety arrangements provided in the building.

During the inspection, it was also observed that the building complex is comprised of three blocks: old block and two new blocks (Block- A, Block- B) & one Multi Purpose Hall. Old block, comprised of ground plus two upper floors and SPS sheds, was issued shortcomings by this department vide letter No. F.6/DFS/MS/School/2015/25 dated 02.01.2015.

New Blocks (Block- A & Block- B) are comprised of ground plus three upper floors and Multi Purpose Hall is comprised of ground floor only. Block A is served by three nos. of staircases having width 1.80 mts each and Block B is served by two nos. of staircases having width 1.80 mts each. However, following fire safety arrangements are required: -

1. First aid hose reel is provided in blocks but all found non-functional.
2. Overhead water storage tank capacity 10000 lts provided on old block found empty.
3. Terrace pump found removed on old block. In Block A & B, terrace pump is provided but found non-functional.
4. Exit signages found missing at various places in all blocks.
5. Some Fire extinguishers checked/ tested were not found in working condition.

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

(Dharampal Bhardwaj)

Dy. Chief Fire Officer (WZ)

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

for information please.