

C-40

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2021/SZ/ 357

Dated: 19/7/21

To,

The Principal,
Ring Midways Sr. Sec. Public school,
Main Najafgarh Road, Palam More,
Vipin Garden, New Delhi-110059.

Sub: - Regarding grant of NOC from fire safety point of view in r/o Ring Midways Sr. Sec. Public school at Main Najafgarh Road, Palam More, Vipin Garden, New Delhi-110059.


Sir,

Please refer to your letter no. NIL Dated -15/06/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above-mentioned school building from fire safety point of view. During the course of inspection, the following points / shortcomings were noticed:

1. First aid hose reel provided but not functional.
2. Down comer system provided but not functional.
3. Fire Pump provided but not functional & auto mode.
4. Exits signage's not provided

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage .Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. Director of Education,
GNCT of NCT of Delhi, Old Secretariat,
Delhi-110054.