

C-24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/School/2021/WZ/ 356

Dated: 19/7/21

To,

The Principal,
Shanti Vidya Niketan School,
Ishwar Colony, Delhi-110039.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Shanti Vidya Niketan School, Ishwar Colony, Bawana, Delhi-110039.

Sir,

This has reference to your e mail id dated 09.06.2021 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 23.06.2021 to see the compliance of the requisite fire safety measures. Sh. Vivek Sharma (Principal) was present at the time of inspection. During the course of inspection it was observed that school building comprised of ground floor plus two upper floors and was issued FSC by this department vide letter no.F6/DFS/MS/2018/1309 dated 05.06.2018 for a building of Ground+First floor. Your request of issue of FSC is rejected as the following shortcomings were observed:-

1. Width of staircase found 1.30 m against required width of 1.50 m.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully,


(Atul Gang)
Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054