

G53

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/362

Dated: 23/07/2021

To,

The Principal,
Mount Abu Public School,
Sector-5, Pkt.-B-8, Rohini,
Delhi-85.

Sub: Issue of FSC in r/o Mount Abu Public School, Sector-5, Pkt.-B-8, Rohini, Delhi-85

Sir,


Kindly reference to online e-mail dated 22.06.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 09.07.2021, in presence of Mrs Jyoti Arora, (Principal) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Access to alternate staircase at terrace found removed.
2. Minor changes found observed on terrace of second floor by adding rooms.
3. Temporary classrooms in porta-cabin found to be constructed at terrace.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

01
24