

C 28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

No. F6/DFS/MS/School/WZ/2021

369

Date 27/07/2021

To,

The Principal,
Sarvodaya Kanya Vidyalaya,
A-Block, Keshavpuram, Delhi-110035.

Subject: - Regarding renewal of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya, Located at A-Block, Keshavpuram, Delhi-110035.

Sir,

Please refer to your letter no. SKV/KP/737 dated 21.06.2021 on the subject cited above. In this connection it is to inform you that the said building have been inspected by the officer concerned of this department on 14.07.2021 in presence of Ms. Anita Sardana (Principal) to check compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/School/2015/1937 dated 21.08.2015 (copy enclosed).

During inspection, it has been observed that the above said shortcomings have not been rectified yet.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

OK

27/07/2021

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

024

No.

FG/DFB/MS/school/2015/1937

Dated: 21/08/2015

To

The Principal,
Govt.Sarvodaya Girls SR. Sec. School,
A- Block, Keshav Puram, Delhi- 110035

Sub: - Inspection report in respect of Govt.Sarvodaya Girls SR. Sec. School, A- Block, Keshav Puram, Delhi- 110035

Sir,

Please refer to your letter no. GSKV/KP/A BIK Dated 09/07/2015 on the subject noted above. In this connection, it is informed that the said school premises have been inspected by the officer concerned of this department on 04-07-2015 in the presence of Smt. Rajdulari Sharma (Vice Principal)

The following shortcoming was observed during the time of inspection:-

1. Hose Reels found nonfunctional.
2. Fire Extinguishers found nonfunctional.
3. PA system found nonfunctional.
4. Internal Hydrant System found nonfunctional
5. Two Pumps of 900 lpm & 180Lpm found nonfunctional.
6. Hose boxes found damaged hoses found missing.
7. The Electric wiring in the school is not laid in metal conduit or concealed type.

You are requested to comply the above mentioned shortcomings with in 90 days under intimation to this department for further necessary action. The Period shall be at your risk and cost.

Yours faithfully

(Vipin Kewal)

Dy. Chief Fire Officer

Phone:-23846352

0/20
11/8