

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/SZ/ 365

Dated: 23/07/2021

To

The Principal,
S.D.M.C Nigam School,
Lajpat Nagar- IV, (G),
New Delhi -110020.

Sub: Reg. renewal of Fire Safety Certificate in r/o S.D.M.C Nigam Pratibha School, Lajpat Nagar- IV
(G) New Delhi -110024

Sir,

This is in reference with Gmail Dated 01/07/2021 on the subject cited above. In this regard, school premises have been inspected by officer concerned of this department on dated 14.07.2021 in presence of Mrs. Manju Chagh (Principal) to verify the status of existing fire prevention and fire safety measures. During the course of inspection, the shortcomings observed are as below;

1. First Aid Hose Reels not working.
2. Terrace level pump capacity 450 LPM not working.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Director of Education, SDMC, Civic Centre Minto Road, New Delhi