

G 71

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 479

Dated:-27/07/2021

To,

The Manager
Rajput guest house, 194, Ghee Mandi,
Pahar Ganj, New Delhi

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Rajput Guest house, 194, Ghee Mandi, Pahar Ganj, New Delhi ID No. 2021031511301 dated 15/03/2021.

Sir,

This has reference to on line ID No. 2021031511301 dated 15/03/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 13/07/2021 in the presence of Mr. Bablu and following shortcomings were observed: -

1. First aid hose reel is not provided at each floor.
2. Fire Extinguisher are due for refilling.
3. PA system found non functional
4. Terrace pump found replaced with 225 LPM against the requirements of 450 LPM.
5. FSC shall be issued up to second floor as mezzanine is counted as floor.
6. Fresh Affidavit is also required as per notification dated 27.05.19 & clarification Dated 29.06.2021. .

Further, the building plan as uploaded is not signed by owner itself and section /elevation plans are also not submitted/uploaded for height verification.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

