

e-24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F 6 / DFS / HQ/ 2021/ 360

Dated 23/07/2021

To,

The Principal  
Govt. Girls Sr. Sec. School No-2,  
Shakti Nagar, Delhi-110007.

Sub: - Issuance of Fire Safety Certificate in r/o Govt. Girls Sr. Sec. School No-2, Shakti Nagar, Delhi-110007. (School I.D-1207038)

Sir,

This has reference to your letter received through email I D dated 22.06.2021 on the subject cited above. In this connection this is to inform you that the above said premise was visited by the officer concerned of this department on 24.06.2021 and observed that requisite reply has already been furnished vide this department letter of even no. 2149 dated 18.05.2018 (copy enclosed).

However, a copy of the same is enclosed herewith for your information please.

Yours faithfully

(AtulGarg)  
Director

Ph: 011-23414250

o/c

Copy to:-

1. ggsss1207038@gmail.com

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

220

No. F6/DFS/MS/2018/2149

Dated: 18/5/18

To,

Head of School,  
Govt. Girls Sr. Sec. School No.-2,  
Shakti Nagar, Delhi-110007.


**Sub.:- NOC in r/o Govt. Girls Sr. Sec. School No.-2 (ID-1207038), Shakti Nagar, Delhi-110007.**

Sir,

With reference to your letter No. GG/SSS/SN2/1054 dated 17/03/2018 on the subject cited above. In this connection it is to inform you that the premises was visited by the officer of this department on 07/05/2018 in the presence of Sh. P.C. Sehgal (Estate Manager) and found that shortcomings issued by this department vide letter No. F6/DFS/MS/2013/School/2051 dated 21/08/2013 still not complied. (Copy Enclosed)

In view of above Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



**ATUL GARG,  
DELHI FIRE SERVICE**



C-10

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

**NO. F-6/DFS/MS/2013/School/2051**

**Date: 21 / 08 / 2013**

To

The Principal,  
Govt. Girls Sr.-Sec. School,  
No.-2, Shakti Nagar,  
Delhi- 110007.

**Sub:** -Regarding fire safety certificate in respect of Govt. Girls Sr.-Sec. School, no.-2, Shakti Nagar, Delhi-110007.

Sir,

Please refer to your letter no. GG/SSS/SNO.2/1070 dated 18/07/13 on the subject cited above. In this connection it is to inform you that the inspection of above said premises was carried out by the officer concerned of this department along with school authority on 18/07/2013 from fire safety point of view and following shortcomings were observed.

1. Hose reels not provided in block comprising ground + two upper floors.
2. Overhead water tanks capacity of 5000 ltr is provided against 10,000 ltr.
3. Terrace pump is not an auto mode.

In view of above fire safety certificate cannot be considered at this stage. You are requested to provide the fire safety arrangements as per the Circular of Director of Education.

Yours faithfully

*VIPIN KENTAL*  
(VIPIN KENTAL)  
Dy Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23846352  
[dcfowz.dlfire@nic.in](mailto:dcfowz.dlfire@nic.in)

Copy to:

1. The Director of Education, Old secretariat, Delhi- 110054.
- acc*