

C-23

02/08/2021

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021 /388

Dated: 02/08/2021

To,

The Principal,
N.K Bagrodia Global School,
Sector – 17, Phase – II , Dwarka,
New Delhi – 110078

Subject: Renewal of Fire Safety Certificate iro N.K Bagrodia Global School, Located at,
Sector – 17, Phase – II , Dwarka, New Delhi – 110078.

Sir,

Please refer to your letter no. NKGBS/DFS/2021-22 Dated 09/06/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 05/07/2021 in presence of Mrs. Jaishree Nawani for fire safety point of view.


During the course of inspection following shortcomings are observed.

1. Exit Doors of the stairs are found locked at terrace level. All the Exits must be clear from any obstruction and free from lock and key.
2. The terrace pump found nonfunctional in auto mode.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Sunil Chaudhary)
Dy. Chief Fire officer
Delhi Fire Service

Copy to:-

Directorate of Education Old Secretariat Delhi – 110054

