

e/15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2021/387

02/08/2021
Dated: 02/08/2021

To,

The Principal,
Rajkiya Pratibha Vikas Vidhalaya,
Sector – 05, Dwarka,
New Delhi.

Subject: Renewal of Fire Safety Certificate iro Rajkiya Pratibha Vikas Vidhalaya Located at,
Sector – 05, Dwarka, New Delhi.

Sir,

Please refer to your letter no. Email dated 01/07/2021 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the team of officers from this department on 22/07/2021 for the renewal of fire safety certificate. During course of inspection the following shortcomings were observed:

1. Fire service inlet was found damaged.
2. Fire extinguishers found empty.
3. The Hose reel Hose found nonfunctional
4. Terrace pump of 450 LPM found not functional and not in auto mode.
5. The down commer line found leaking

In view of the above shortcomings Fire Safety Certificate can not be considered at this stage.

You are requested to comply the abovementioned shortcomings under intimation to this department.

Yours faithfully,

(Sunil Chaudhary)

Dy. Chief Fire officer
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054