

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO.F6/DFS/MS/School/2021/NDZ/ 386

Dated: 02/08/2021

To,

The Principal,
S. R. Capital Public School,
Q-Block, Mohan Park,
Naveen Shahdara, Delhi-110032

Subject:- Renewal of Fire Safety Certificate.


Sir,

With reference to your email ID ujjwal8589@gmail.com dated 01/07/2021 on the subject cited above, it is informed that to ensure proper implementation of fire prevention and fire safety measures under rule 33 of DFS Rules-2010, following information/documents pertaining to the premises/building are required:-

1. Sanctioned/Completion plans or,
2. As built plans (on the scale of 1:100 having details of height/covered area, year of construction/conversion of occupancy duly marked with fire and life safety arrangements as stipulated under Rule 33 of Delhi Fire Service Act of Rules 2010) through building/local authority, in case sanctioned/completion plans are not available.
3. Initial date of operation of educational occupancy in the building.

Thus, you are requested to provide above mentioned information/documents at the earliest for further consideration.

Yours Faithfully,


30/7/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer



Copy to:-

The Joint Director of Education (Land & Estate),
Directorate of Education,
Lucknow Road, Delhi-110054