

G-43

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2021/ 392

Dated: 04/08/2021

To,

The Principal,  
N.K Bagrodia Public School,  
Sector - 4, Dwarka,  
New Delhi - 110078.

Subject: Renewal of Fire Safety Certificate iro N.K Bagrodia Public School, Located at Sector - 4, Dwarka, New Delhi - 110078.

Sir,

Please refer to your letter no. Form J Dated 07/06/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 05/07/2021 in presence of Dr. Rajee N Kumar (Principal) for fire safety point of view.

During the course of inspection following shortcomings are observed.

1. Six mtrs road around the building found encroached/ partially removed.
2. One portion of the building at Basement & ground level occupied by the Bank. The stairs cases in the bank are found locked.
3. Smoke Exhaust fans are found removed in the basement.
4. The passage to the stair is given through class rooms/ Labs. Exit/ Passage must be clear from any obstruction.
5. The Pumps are found nonfunctional in auto mode.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:- Directorate of Education Old Secretariat Delhi - 110054

2/8/21