

C-8U

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 377

Dated: 30/07/2021

To,

The Principal,  
N.K. Bagrodia Public School,  
Sector-9, Rohini,  
Delhi-110085.

**Sub:** Issue of FSC in r/o N.K. Bagrodia Public School, Sector-9, Rohini, Delhi-110085.

Sir,


Kindly reference to online e-mail dated 11.03.2021, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 26.03.2021, in presence of Sq. Ldr (Retd.) P.K Slawan, Admin Officer, to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire check doors are found removed in basement.
2. Automatic Sprinkler System found removed at some places in basement.
3. Over Head fire water captive tank capacity found 25,000ltr against the required capacity of 30,000 ltrs.
4. Exit signage found removed at some places.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings or submit sets of building plans on a scale of 1:100 including elevation for entire building through building sanctioning authority i.e MCD/DDA duly marked with fire & life safety provisions as stipulated in NBC. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

  
(Dhrampal Bhardwaj)  
Dy. Chief Fire Officer  
Tel:-01123414250

ae  
My