

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/Hotel/2021/NDZ/ 24

Dated: 2/8/21

To,

Mr. Daksh Dhawan,
Aman Hospitality Pvt. Ltd.,
Hotel Building, Plot No. 1,
Central Business District, Shahdara, Delhi

Subject:-Application for renewal of Fire Safety Certificate in respect of the Hotel Building at Plot No. 1, Central Business District, Shahdara, Delhi.

Sir,

With reference to your email ID dakshd@gmail.com dated 21/06/2021 on the subject cited above, it is informed that officers concerned of this department inspected the premises from fire safety point of view in presence of Sh. Arnab Mondal (Chief Engineer) and Sh. Parmeet (Fire Officer) on dated 13/07/2021 & 14/07/2021. The building comprises of three basement, ground mezzanine plus twelve upper floors. During the course of inspection following observation were made:-

1. Automatic sprinkler system found removed in some areas in basement. Same should be extended in basement in all area.
2. Fire detection & alarm system and fire suppression system found non functional at mezzanine, first and second floor.
3. Fire hydrant and hose reel to be extended to cover DG room/ substation.
4. Water curtain system in the basement found non functional.
5. Lift signage to be provided at all lifts.
6. Electrical riser shaft & other shafts required to be sealed at all floor level.
7. Fire Check doors found damaged at various locations, same should be repaired.
8. Hose reel found removed at terrace level.
9. Terrace pump is not accessible.
10. Exit signage required to be provided at all exits.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,

(Atul Darg)
Director

9/8/21