

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 393

Dated: 04/08/2021

To,

The Principal,  
Karan Public School,  
C-530, Aman Vihar, Kirari,  
Delhi-86

**Sub:** Issue of FSC in r/o Karan Public School, C-530, Aman Vihar, Kirari Delhi-86.

Sir,


Kindly reference to online mail dated 12.11.2020, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **23.07.2021**, in presence of **Miss. Shikha (Teacher)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Alternate staircase of 1.50 mtr is not provided.
2. Fire protection arrangements as per NBC part-IV are not provided.
3. MOEFA is not provided.
4. Terrace Fire pump with capacity 450 LPM not provided.
5. 10,000 ltrs Over-Head fire water tank not provided.
6. Exit signage's not provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully

  
(Dharmpal Bhardwaj)  
Dy. Chief Fire Officer  
Ph: 011-23414250

o/c  
SPP  
02/8/2021