

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/WZ/2021/ 389

Dated: - 02/08/2021

To

The Assistant Engineer (E)
Sub-Div-1 Education Divn M1 (N),
PWD GNCT, Govt. of Delhi,
ITI Campus, Pusa, New Delhi

Sub.: - Regarding renewal of Fire Safety Certificate in r/o Govt. Girls Sr. Sec. School located at Ambica Vihar, Delhi-110087.


Sir,

This is in reference to your letter no. 54(SPS School)/PWD Edu. Sub-Divn M1-1(N)/2021-22/72 dated 21/06/2021 received in this department through Outdoor Diary no. 1285 dated 24/06/2021 on the subject cited above. In this connection, it is to inform you that the school building have been inspected by the officer concerned of this department in presence of Mr. Shikari (M/s Arihant builders) on 09/07/2021 to check the fire safety arrangements provided in the building. During the inspection, it was also observed that the building complex is comprised of Ground + three upper floors. The following shortcomings have been observed:

1. Hose Reels nozzles are not provided.
2. Fire Pump on terrace found is not energized.
3. Overhead tank has capacity 10,000 ltrs found empty.
4. Exit Signages are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.


Yours faithfully


(Atul Garg)

Director
Delhi Fire Service

Copy to: -

1. The Director of Education, NDMC, Civic Centre, Minto Road, New Delhi.


27/7/21