

C-14

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/HQ/2021/379

Dated 30/07/2021

To,

The Principal  
Mata Ramrakhi Sanatan Dharam  
Saraswati Bal Mandir, C-67, Mahendru  
Enclave, Delhi-110033.

Sub: - Regarding issuance of fire safety certificate in r/o Mata Ramrakhi Sanatan Dharam  
Saraswati Bal Mandir, C-67, Mahendru Enclave, Delhi-110033.


Sir,

Please refer to your letter received through email I.D dated 05.07.2021 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 16.07.2021 to verify the fire safety measures issued vide Director of Education and observed that the school premise is comprised of ground and two upper floors. At the time of inspection Mrs. Neelam Patial (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. The main gate of the school building is 1.60m provided against the requirement of width 2.50m.
2. Hose reel hose provided but not functional at the time of inspection.
3. MOEFA system not provided.
4. Terrace level firefighting pump capacity of 450lpm provided but not functional at the time of inspection. Fire pumps are not on auto mode/emergency electrical supply.
5. Terrace level fire water tank of capacity 10,000ltrs is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.
6. Exit signage's and floor signage not provided at strategic location in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage

Yours faithfully

  
(Atul Garg)  
Director

Ph: 011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.