

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/376  
To.

Dated: 30/07/2021


The Principal,  
De Indian Public School,  
Pocket-II, Sector-24, Rohini,  
Delhi-110085.

**Sub:** Issue of FSC in r/o De Indian Public School located at Pocket-II, Sector-24, Rohini, Delhi-110085.

Sir,

Kindly reference to online e-mail dated 23.07.2021, received in this department on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 5540 dated 12.09.2019 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 12.09.2019 for further consideration in this matter.

Yours Faithfully



(Dhrampal Bhardwaj)  
Dy.Chief Fire Officer  
Tel:-01123414250

o/c  
Dy

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

NO. F. 6 / DFS / 2019 / 5590

Dated. 12/9/19

To,

The Principal,  
De Indian Public School,  
Pocket-11, Sec- 24, Rohini, Delhi-85.

Sub: - Regarding issuance of fire safety certificate in r/o De Indian Public School Pocket-11, Sec- 24, Rohini, Delhi-110085.

Sir,

Please refer to your letter no. dairy no. 15032 dated 09.06.2019 on the subject cited above. In this connection, this is to inform you that the above mentioned site was visited by the officer concerned of this department to verify the fire safety measures installed in the building . At the time of inspection Mrs. Seema Awasthi, Principal was also present at the site. The observation made during the visit are as under:

1. There is the addition/ alteration seen in the building. As per earlier approval the bulding was comprised of Basement, Ground & two upper floor's and now the building is comprised of basement, ground & 04 upper floor.
2. The third floor of the building is being used for classes as per earlier FSC school activitiy was restricted up to 2<sup>nd</sup> floor of the building.
3. The basemsnt of the building is also being used for as auditorium/ dancing & assembly activity.

Hence, you are requested to submit two sets of approved building plans drawn on the scale of 1:100 or otherwise refer your case through concerned building licensing authority i.e. North Delhi Municipal Corporation, for further consideration in the matter.

This is for your information and action at your end please.

Yours faithfully

(Dharmpal Bhardwaj)

Dy.Chief Fire Officer

Ph: 011-25104544

Copy to:-

1. The Executive Engineer, MCD, Building department, 8<sup>th</sup> floor, Civic Centre, Minto Road, New Delhi-01.