

C-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2021/WZ/375

Dated: 30/07/2021

To

The Principal
USM Public School
Veena Enclave, Nangloi
New Delhi.


Sub: Reg. issue of Fire Safety Certificate in r/o USM Public School located at plot no. 3/47, 48, Veena Enclave, Nangloi, New Delhi-110041.

Sir,

This has reference to your Email dated 13/07/2021 received in this department on the subject cited above. In this connection, it is informed you that the school building was inspected by the officer concerned of this department to check the status of the shortcomings pointed out by this department vide letter no. F.6/DFS/MS/School/2021/WZ/197 dated 07/04/2021, F.6/DFS/MS/School/2014/1204 dated 04/06/2014 & F.6/DFS/MS/2013/1919 dated 08/08/2013 (Copy enclosed), but no improvement was observed as seen during the course of inspection.

In view of above, your request for grant of fire safety certificate is rejected. You are advised to comply the shortcomings mentioned in the letter dated 08.08.2013 under intimation to this department. Till such time, running a school without a valid fire safety certificate will be at your risk and responsibility.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to:

1. The Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002.

C-17 C-8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

No. F6/DFS/MS/2013/1979

Dated 8/8/13

To

The Manager,
U.S.M. Public School (Recognized),
Veena Enclave, Nangloi,
New Delhi -110041.

Sub:- Inspection report in respect of U.S.M. Public School (Recognized), Veena Enclave, Nangloi, New Delhi -110041 from fire & safety point of view.

Sir,

With reference to your letter No. Nil dated 29/05/2013 on the subject noted above, it is informed that the said school premises was inspected by the officer concerned of this department on 10/07/2013 in the presence of Smt. Sunita (Teacher).

During inspection it has been observed that the school premises was earlier issued FSC by this department vide letter No. F6/MS/DFS/06/3277 dated 07/11/2006 for ground floor only. Now school management has added 1st floor & 2nd floor on existing ground floor. Fire Safety arrangements such as Fire Extinguishers were found provided only.

The following shortcomings were observed during the time of inspection:-

1. First Aid Hose Reel on each floor has not been provided.
2. Terrace pump of 450 LPM capacity has not been provided.
3. Over Head Tank of 10,000ltr. has not been provided.
4. Exit signage not provided.
5. The width of both the staircase is to be increased up to 1.50mtr.

The School premises is not meeting the requirement of Fire & Safety guidelines issued by the Directorate of Education circular dated 01.03.2011.

In view of above, Fire Safety Certificate from the Fire & Safety point of view cannot be considered at this stage.

Yours faithfully


(Sanfokh Singh)
Chief Fire Officer
Delhi Fire Service
Phone:-23414250
E-mail: cfowz.dlfire@nic.in

Copy to :-

1. The Director of Education, Gov. of NCT of Delhi, Old Secretariat, Delhi.