

C-103

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/391

Dated: 04/08/2021

To,

Sh. Thomas George,
Admin Officer,
Mount Carmel Sr. Secondary School,
Sector – 22, Dwarka Phase – 1,
New Delhi – 110077.

Subject: Renewal of Fire Safety Certificate iro Mount Carmel Sr. Secondary School
Located at, Sector – 22, Dwarka Phase – 1, New Delhi – 110077.

Sir,

Please refer to your letter no. Email dated 01/07/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 08/07/2021 in presence of Mr. Thomas George (Admin Officer) for fire safety point of view.

During the course of inspection flowing shortcomings are observed.

1. The 6 mtr wide road around the building found not clear due to plantation and poles etc. The same must be removed.
2. Fire check door found not provided at some places.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Anil Garg)
Director
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054.