

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/2021/ 407

Dated: 09/08/2021

To

The Principal,  
EDMC Primary School,  
Mayur Vihar, Phase-1, Pocket-1,  
Shahdara South Zone, Delhi.


**Sub: Regarding grant of FSC in r/o EDMC Primary School, Mayur Vihar, Phase-1,  
Pocket-1, Shahdara South Zone, Delhi.**

Sir,

This has reference to email dated 23/07/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 27/07/2021 in the presence of Mrs. Vinita Bhatia (Principal) & Mr. Rakesh Kumar (Teacher) and observed that earlier the building was Ground floor only, now the building is Gr. + 02 upper floors, hence it is the case of addition/alteration. The concerned is requested to submit approved/as built building plans through building sanctioning authority/local authority in scale 1:100 with existing fire safety arrangement.

Hence, Fire Safety Certificate can not be considered at this stage.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

The Director (Education),  
Govt. of NCT, Old Sectt.  
Delhi - 54.

ge  
m