

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/School/NDZ/2021/ 394

Dated: 05/08/2021

To,

The Principal,
Sarvodaya Kanya Vidyalaya,
C-Block, Vivek Vihar, Delhi-110095
School ID-1001022

Subject:- Renewal of fire safety certificate with respect to SKV Vivek Vihar.

Sir,

With reference to email ID 1001022hos@gmail.com dated 05/07/2021 on the subject cited above, it is informed that officer concerned of this department inspected the building on 29/07/2021 in presence of Ms. Renu Sharma, Principal. It was observed that the shortcomings issued vide letter No F.6/DFS/MS/School/2020/787 dated 21/12/2020 & F.6/DFS/MS/NDZ/2021/199 dated 09/04/2021 have not been complied as yet (The Copy of the same is enclosed for your reference).

Therefore, you are requested to rectify the above shortcomings communicated vide above mentioned letter under intimation to this office for further action.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053

C-28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/School/2020/ 787

Dated: 21/12/2020

To,

The Principal,
Sarvodaya Kanya Vidyalaya,
C-Block, Vivek Vihar, Delhi-110095
School ID-1001022

Sub:- Regarding renewal of Fire Safety Certificate .

Sir,

With reference to your email ID 1001022hos@gmail.com dated 25/11/2020 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Renu Sharma, Vice Principal of the School on dated 04/12/2020. The School building comprises of A block ground plus one, B & C block ground plus three upper floor. During the course of inspection following observations were made:-

1. Firefighting system which has been provided in the building, was not found functional at the time of inspection.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,


21/12/2020

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

AS.
16/12

Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053