

C35

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2021/ 408

Dated: 10/08/2021


To,  
The Principal,  
Indian Convent School,  
T Sec-24, Pocket-3, Rohini,  
Delhi -85

**Sub:** Issuance of Fire Safety Certificate in r/o Indian Convent School, Sec-24, Pocket-3, Rohini, Delhi-85.

Sir,

Kindly reference to online mail dated 19.03.2021, received in this department on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 651 dated 30.09.2020 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 30.09.2020 for further consideration in this matter.

Yours Faithfully



(Dhrampal Bhardwaj)  
Dy. Chief Fire Officer  
Tel:-01123414250

etc  
M

C34-22

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2020/ 651

Dated: 30/09/2020

To

The Principal,  
Indian Convent School,  
Sec-24, Pocket-3, Rohini,  
Delhi-85

Subject: Issuance of Fire Safety Certificate in r/o Indian Convent School, Sec-24, Pocket-3, Rohini, Delhi-85.

Sir,

This is in reference to online email id dated 18.07.2020, on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr Deepak Vasishth, School manager on 18.08.2020 to verify the compliance of fire prevention and fire safety measures required under the rules. The renewal of FSC is rejected under Rules 37, in the view of reasons mentioned below:

1. Additional construction found to be done on third floor by adding some rooms resulting in affecting the fire & life safety measures.


In this regards as stipulated in sub Rule (1) of Rule 37 of DFS Act-2007 & Rules 2010 you are advised to apply again in Form "I" and it shall be accompanied with a certificate from the architect and owner/ occupier that all the fire prevention and fire safety measures as required under Rule 33 have been incorporated in the building and the building/ premises are in best repairs **after restoration of existing building in conformity with the approved sanctioned plans/ pervious FSC.**

**OR**

You may first apply with concerned building sanctioning authority under clause 2.3 of UBBL-2016 under Addition/ Alteration for approval of existing building, afterward you may apply for issue of OCC under clause 2.6 of UBBL-2016 and this department will communicate the status of FSC or its rejection under Rule 35 of DFS Rule-2010, to the building authority and the owner/ applicant as mandate in clause 2.7.7 of UBBL-2016.

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully



(Atul Garg)  
Director

Tel:-01123414000



Copy to:-

The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.