

C-22

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/SZ/2021/ 414

Dated: 16/08/2021

To,

Sh. Jagat Singh Lochab (Chairman)  
Fouji Model School,  
F-8, Mahavir Enclave -III (Madhu Vihar)  
New Delhi - 110059.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o the Fouji Model School, Located at F-8, Mahavir Enclave -III (Madhu Vihar) New Delhi - 110059.

Sir,

Please refer to your letter no Email Dated 02-02-2021 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officer concerned of this department on 09/04/2021. During the course of inspection followings shortcoming have been observed:-

1. The width of class Room doors is less than required 1mtrs clear width

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Atul Garg)  
Director

Delhi Fire Service

Copy to; - Director of Education, Old Secretariat, Delhi-110054

13/8/21