

C-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI – 110001**

No.F.6/DFS/MS/SZ/2021/ 412

Dated: 13 /08/ 2021

To,

Smt. Sunita Nijhawan (Principal),  
S.D.M.C Primary Model School,  
Raj Nagar-Extension – II, Palam Colony,  
New Delhi – 110077.

Subject: Renewal of Fire Safety Certificate iro S.D.M.C Primary Model School, Located at  
Raj Nagar-Extension – II, Palam Colony, New Delhi – 110077.

Sir,

Please refer to your Email dated 14/07/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 02/08/2021 for fire safety point of view.

**The following shortcoming was observed during the time of inspection:-**

1. Hose reel hose found non functional
2. Terrace pump found nonfunctional.
3. Over head water tank of 10,000 ltr capacity found empty.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service.

Copy to; - Directorate of Education Old Secretariat Delhi – 110054

Wok  
13/8/21