

053

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F6/DFS/MS/School/2021/SZ/ 417

Dated: 16/08/2021

To,

The Principal,
Govt. Boys Sr. Secondary School,
Baprola, New Delhi-110043.

Sub: - Regarding grant of NOC from fire safety point of view in r/o Govt. Boys Sr. Secondary School, Baprola, New Delhi-110043.


Sir,

Please refer to your letter no. NIL Dated -23/07/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above-mentioned school building from fire safety point of view. During the course of inspection, the following points / shortcomings were noticed:

1. Fire Pump having 450 lpm provided but not functional in APJ Abdul Kalam block & Radha Krishan block.
2. Exits signage's are not provided.
3. Passage lead to new block is blocked by parking shed.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage .Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

9/8/21

Copy to:-

1. Director of Education, GNCT of NCT of Delhi, Old Secretariat, Delhi-110054.